



SATRA Technology Centre Ltd
Wyndham Way, Telford Way, Kettering,
Northamptonshire, NN16 8SD United Kingdom
Tel: +44 (0) 1536 410000
email: info@satra.com
www.satra.com



TECHNICAL REPORT

Digiprint supplies c/o BMG Media Source SL Ronda General Mitre 28-30 Barcelona BJ-08017 Spain	SATRA reference:	FLO9422P7D0	
	Report ID/Issue number:	241	1
	Your reference:	35735/1	
	Date samples received:	03/01/2024	
	Date(s) work carried out:	03/01/2024 to 11/01/2024	
	Date of report:	15/01/2024	

Testing Requirements

Testing of one product described by the customer as "DIGIMEDIA Removable Adhesive Fabric" to EN 16165:2021 Annex B.

For SATRA's full terms and conditions see our website: https://www.satra.com/terms_of_business.php

For SATRA's statements regarding the confidentiality, publication and dissemination of this report, decision rules and UKAS accreditation please see the final page of this technical report.

Report Signed by:

Reece Johnson


Report Signatory

**TESTING OF ONE SAMPLE DESCRIBED BY THE CUSTOMER AS
“DIGIMEDIA REMOVABLE ADHESIVE FABRIC” TO EN 16165:2021 ANNEX B –
SHOD RAMP TEST.**

As requested by Digiprint Supplies, an assessment has been conducted to determine the slip potential of the sample submitted referenced “Digimedia Removable Adhesive Fabric” using the shod ramp method, as detailed below.


SUMMARY

When tested in accordance with the requirements as described in EN 16165:2021 Annex B, the floor sample submitted under the reference “Digimedia Removable Adhesive Fabric” has demonstrated a ramp test value, α_{shod} , of 12°.

When the results of this testing were assessed in accordance with the National Annex NA in DIN EN 16165:2021 ⁽²⁾, the sample met the requirements for an **R 10 rating**.

SAMPLE SUBMITTED

Sample reference: “Digimedia Removable Adhesive Fabric” ⁽¹⁾
Surface structure: Smooth (Embossed)
Appearance:



Date received: 03 January 2024
Testing completed: 11 January 2024
Testing conducted by: Phil Weal & Tom Notley

TESTS CARRIED OUT

- EN 16165:2021. Determination of slip resistance of pedestrian surfaces – Methods of evaluation. Annex B – Shod ramp test

Notes:

- The information supplied by the customer. Not verified by SATRA.*
- Results assessed in accordance with the German National Annex NA (informative) included in DIN EN 16165:2021, as the information relating to R rating classification is not included in EN 16165:2021.*

RESULTS:

Testing of sample, described by the customer as “Digimedia Removable Adhesive Fabric”, in accordance with EN 16165:2021 Annex B – Shod Ramp Test.

Test No.	Operator A (°)	Operator B (°)
1	11.4	12.1
2	11.5	11.8
3	11.5	12.0
Operator Mean ($\alpha_{0,j}$)	11.5	12.0
Operator Correction Factor (D_j)	0.1	0.0
Corrected Ramp Test Value (α_{shod})	12°	
R Rating (DIN EN 16165:2021) ⁽²⁾	R 10	

DIN EN 16165:2021 National Annex NA, NA.2 Classification of the results by shod ramp test ⁽²⁾.

The assignment of the test result (α_{shod}) of the method according to EN 16165:2021 Annex B, can be carried out in accordance with Table NB.2.

Table NB.2 – Assignment of the test result α_{shod} , to the classes of slip resistance

Test result α_{shod}	Slip resistance class
$6^\circ \leq \alpha_{shod} < 10^\circ$	R 9
$10^\circ \leq \alpha_{shod} < 19^\circ$	R 10
$19^\circ \leq \alpha_{shod} < 27^\circ$	R 11
$27^\circ \leq \alpha_{shod} < 35^\circ$	R 12
$35^\circ \leq \alpha_{shod}$	R 13

Annex 1.0

Operator Verification results for EN 16165:2021 Annex B.

Operator A

Verification Board	Operator A Verification				
	Test Run			Average	Difference
	1	2	3		
St-I (8.0 ± 3.0)	7.5	7.9	8.0	7.8	0.2
St-II (19.9 ± 3.0)	20.3	20.1	19.9	20.1	0.2
St-III A (25.7 ± 3.0)	26.5	26.6	26.1	26.4	0.7

Operator B

Verification Board	Operator B Verification				
	Test Run			Average	Difference
	1	2	3		
St-I (8.0 ± 3.0)	8.2	8.1	8.2	8.2	0.2
St-II (19.9 ± 3.0)	19.5	19.7	19.2	19.5	0.4
St-III A (25.7 ± 3.0)	27.0	26.9	27.2	27.3	1.3

Conditions of Use

Confidentiality and Dissemination

SATRA test reports may be forwarded to other parties provided that they are not changed in any way and are not marked as confidential. Test reports must not be published, for example by including it in advertisements, without the prior, written permission of SATRA.

Liability

Results given in this report refer only to the samples submitted for analysis and tested by SATRA. Comments are for guidance only.

A satisfactory test report in no way implies that the product tested is approved by SATRA and no warranty is given as to the performance of the product tested. SATRA shall not be liable for any subsequent loss or damage incurred by the client as a result of information supplied in the report.

Accreditation

Where the UKAS logo is included on the test report then tests marked ≠ fall outside the UKAS Accreditation Schedule for SATRA. Where no UKAS logo is included on the test report then none of the tests reported are covered by SATRA's UKAS Accreditation.

Tests marked ¥ are performed under SATRA's Flexible UKAS Schedule.

Uncertainty of Measurement and Decision Rules

Where values for uncertainty of measurement are included within the report then the uncertainty of the corresponding results are based on a standard uncertainty multiplied by a coverage factor $k=2$, which provides a coverage probability of approximately 95%.

When reporting results against a conformance statement (Pass/Fail or the allocation of a class or level) then uncertainty of measurement is taken into account based on a non-binary acceptance which itself is based on the guard band being equal to the expanded uncertainty.

Where the result corrected for uncertainty falls within the tolerance of the conformance statement then the risk of the conformance statement being a false accept or false reject is up to 2.5% and SATRA will in this instance quote a Pass/Fail, class, or level.

Where the result corrected for uncertainty falls outside of the tolerance of the conformance statement then the risk of the conformance statement being a false accept or false reject is up to 50%. In this instance SATRA will not provide a Pass/Fail statement or a class or level but will include information in the notes in relation to the result obtained.

Where a report contains SATRA guidelines values then uncertainty of measurement values have been taken into account when determining the guideline values and as such are not considered when determining pass/ fail criteria.
